

Chemical	2009 EPA Advisory Level	2016 EPA Advisory Level	2022 EPA Advisory Level	2024 EPA MCL	AWWB Sample Results (Estes WTP)	AWWB Sample Results (Well No. 3)	AWWB Sample Results (Well No. 4)
PFOA	400 ppt	70 ppt (combined with PFOS)	0.004 ppt	4 ppt (0 ppt MCLG)	Not Detected	8.43 to 13.3 ppt (10.4 avg)	Not Detected
PFOS	200 ppt	70 ppt (combined with PFOS)	0.02 ppt	4 ppt (0 ppt MCLG)	Not Detected	1.4 to 4 ppt (3.1 avg)	Not Detected
PFHxS	N/A	N/A	N/A	10 ppt	Not Detected	ND to 3.2 (1.8 avg)	Not Detected
PFNA	N/A	N/A	N/A	10 ppt	Not Detected	ND to 1.8 (0.7 avg)	Not Detected
HFPO-DA (GenX)	N/A	N/A	10 ppt	10 ppt	Not Detected	ND to 1.5 (0.6 avg)	Not Detected
PFBS	N/A	N/A	2,000 ppt	Hazard Index = 1 (unitless) (with PFHxS, PFNA, HFPO-DA)	Not Detected	ND to 3.7 ppt (2.1 avg)	Not Detected

*Not Detected (ND) indicates that the result was not detected at or above the laboratory's method detection limit